

Report for:

Mr. Quality Control
EMLab P&K (QA)
1150 Bayhill Drive
Suite 100
San Bruno, CA 94066

Regarding: Eurofins EPK Built Environment Testing, LLC
Project: Sample Report
EML ID: 1012562

Approved by:



Technical Manager
Amin Suliman

Dates of Analysis:

Asbestos-airborne fiber count (NIOSH 7400): 01-10-2013

Service SOPs: Asbestos-airborne fiber count (NIOSH 7400) (EB-AS-S-1260)
AIHA LAP, LLC accredited service, Lab ID #102856

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. The results relate only to the samples as received and tested. Information supplied by the client which can affect the validity of results: sample air volume.

Eurofins EPK Built Environment Testing, LLC ("the Company"), a member of the Eurofins Built Environment Testing group of companies, shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Eurofins EPK Built Environment Testing, LLC's LabServe® reporting system includes automated fail-safes to ensure that all AIHA LAP, LLC quality requirements are met and notifications are added to reports when any quality steps remain pending.

Client: EMLab P&K (QA)
C/O: Mr. Quality Control
Re: Sample Report

Date of Sampling: 01-10-2013
Date of Receipt: 01-10-2013
Date of Report: 01-10-2013

ASBESTOS AND OTHER FIBERS BY PCM: NIOSH 7400 METHOD

Lab ID-Version‡	Volume (liters)	Fibers Detected	Fields Read	Fibers/mm ²	95% UCL*	Fibers per CC
-----------------	-----------------	-----------------	-------------	------------------------	----------	---------------

Location: 2, Office

Comments:

4534221-1	900	< 5.5	100	< 7	< 0.003 (Sr = N/A)	< 0.003
-----------	-----	-------	-----	-----	--------------------	---------

Location: 3, Office

Comments:

4534222-1	900	10	100	12.74	0.009 (Sr = 0.13)	0.005
-----------	-----	----	-----	-------	-------------------	-------

Location: 4, Office

Comments:

4534223-1	900	30.5	100	38.85	0.022 (Sr = 0.05)	0.017
-----------	-----	------	-----	-------	-------------------	-------

Location: 5, Removal

Comments:

4534224-1	150	102	20	649.68	2.059 (Sr = 0.09)	1.668
-----------	-----	-----	----	--------	-------------------	-------

Location: 6, Removal

Comments:

4534225-1	150	< 5.5	100	< 7	< 0.018 (Sr = N/A)	< 0.018
-----------	-----	-------	-----	-----	--------------------	---------

A counting rules used unless otherwise specified in report comments.

Interpretation is left to the company and/or persons who conducted the field work.

Field blanks, if submitted with the project, have been used to correct the data. Omission of 2 field blank samples should be considered a deviation from the NIOSH 7400 method.

Reporting limit is calculated using a minimum detection limit of 7 fibers/mm².

* Upper 95% Confidence Limit for fibers/cc, calculated using a relative standard deviation value (intralaboratory Sr) mentioned above.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".