

Report for:

Mr. Quality Control
EMLab P&K (QA)
1150 Bayhill Drive
Suite 100
San Bruno, CA 94066

Regarding: Eurofins EPK Built Environment Testing, LLC
Project: Sample Report
EML ID: 1013586

Approved by:



Approved Signatory
Amin Suliman

Dates of Analysis:
Asbestos-EPA 400 point count: 01-10-2013

Service SOPs: Asbestos-EPA 400 point count (EPA 40CFR App E to Sub E of Part 763 & EPA METHOD 600/R-93-116, SOP EB-AS-S-1262)
NVLAP Lab Code 200728-0

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. Due to the nature of the analyses performed, field blank correction of results is not applied. The results relate only to the samples as received and tested.

Eurofins EPK Built Environment Testing, LLC ("the Company"), a member of the Eurofins Built Environment Testing group of companies, shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

Client: EMLab P&K (QA)
C/O: Mr. Quality Control
Re: Sample Report

Date of Sampling: 01-10-2013
Date of Receipt: 01-10-2013
Date of Report: 01-10-2013

ASBESTOS POINT COUNT REPORT

Location:	1		
Total Points Counted:	400		
Lab ID-Version‡:	4534726-1		
Sample Layers	Asbestos Type	Asbestos Points Counted	Asbestos Concentration (%)
White Joint Compound	Chrysotile	5	1.25
Layer Totals:		5	1.25

Location:	2		
Total Points Counted:	400		
Lab ID-Version‡:	4534727-1		
Sample Layers	Asbestos Type	Asbestos Points Counted	Asbestos Concentration (%)
Black Mastic	Chrysotile	6	1.5
Layer Totals:		6	1.5

Location:	3		
Total Points Counted:	400		
Lab ID-Version‡:	4534728-1		
Sample Layers	Asbestos Type	Asbestos Points Counted	Asbestos Concentration (%)
Brown Ceiling Tile	Chrysotile	2	0.5
Layer Totals:		2	0.5

The analytical sensitivity is 1 asbestos point. The limit of detection is 1 asbestos point divided by the total number of points counted and multiplied by 100.

The results relate only to the items tested. Interpretation is left to the company and/or persons who conducted the field work. The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government.

All samples were received in acceptable condition unless otherwise noted. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.
Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".

Client: EMLab P&K (QA)
C/O: Mr. Quality Control
Re: Sample Report

Date of Sampling: 01-10-2013
Date of Receipt: 01-10-2013
Date of Report: 01-10-2013

ASBESTOS POINT COUNT REPORT

PROJECT ANALYST AND SIGNATORY REPORT

Project Analyst



Analyst: Malcolm Moody

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government. The Company reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

‡ A "Version" indicated by "-x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".