

Client: EMLab, Inc.
 C/O: Dr. Kamashwaran Ramanathan
 Re: Sample Report; Asbestos Analysis

Date of Sampling: 05-27-2005
 Date of Receipt: 05-27-2005
 Date of Report: 03-06-2006

ASBESTOS PLM REPORT: EPA METHOD 600/R-93-116

Total Samples Submitted: 3
Total Samples Analysed: 3
Total Samples with Composite Asbestos Value > 1%: 2

Location: 1, Insulation

Lab ID-Version‡: 669343-13

Sample Layers	Asbestos Content
Off-White Fibrous Insulation	9% Amosite 7% Chrysotile
Composite Asbestos Fibrous Content:	16% Asbestos
Composite Non-Asbestos Fibrous Content:	40% Cellulose 40% Glass Fibers

Comments: Sample composite homogeneity: Good.

Location: 2, Drywall and joint compound

Lab ID-Version‡: 682013-4

Sample Layers	Asbestos Content
Drywall	ND
White Joint Compound	< 1% Chrysotile
White Skim Coat	ND
Composite Asbestos Fibrous Content:	< 1% Asbestos
Composite Non-Asbestos Fibrous Content:	10% Cellulose 5% Glass Fibers

Comments: Sample composite homogeneity: Moderate.

Location: 3, Floor tile

Lab ID-Version‡: 682014-4

Sample Layers	Asbestos Content
Beige Floor Tile	2% Chrysotile
Yellow Mastic	ND
Composite Asbestos Fibrous Content:	2% Asbestos
Composite Non-Asbestos Fibrous Content:	< 1% Cellulose < 1% Nylon

Comments: Sample composite homogeneity: Good.

The results relate only to the items tested. Interpretation is left to the company and/or persons who conducted the field work. The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government.

All samples were received in acceptable condition unless otherwise noted. EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified.

Inhomogenous samples are separated into homogenous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed.

‡ A "Version" greater than 1 indicates amended data.