

Client: EMLab, Inc.
C/O: Report Contact
Re: Sample Report

Date of Sampling: 01-01-2005
Date of Receipt: 01-02-2005
Date of Report: 01-02-2005

ASBESTOS PLM REPORT: EPA METHOD 600/R-93-116

Location: 1, Stage Ceiling

Lab ID-Version‡	Sample Composite:	
669343-9	Non-asbestos Content	Asbestos Content
	7% Cellulose	5% Asbestos
	Sample Layers:	
	Layer Description	Asbestos Content
	Off-White Semi-Fibrous Material	10% Chrysotile
	Paint	ND

Comments:

Location: 2, HVAC Duct Wrap

Lab ID-Version‡	Sample Composite:	
682013-1	Non-asbestos Content	Asbestos Content
	10% Cellulose	51% Asbestos
	Sample Layers:	
	Layer Description	Asbestos Content
	Light Grey Fibrous Material	55% Chrysotile
	Off-White Fibrous Material	ND
	Silver Foil	ND

Comments:

Location: 3, Accoutic Ceiling

Lab ID-Version‡	Sample Composite:	
682014-1	Non-asbestos Content	Asbestos Content
	Trace Cellulose	5% Asbestos
	Sample Layers:	
	Layer Description	Asbestos Content
	Off-White Semi-Fibrous Material	<1% Amosite 5% Chrysotile
	Paint	ND

Comments: